Texas Commission on Environmental Quality

BACKFLOW PREVENTION ASSEMBLY TEST AND MAINTENANCE REPORT

The following form must be completed for each assembly tested. A signed and dated original must be submitted to the public water supplier for recordkeeping *purposes:

CUSTOMER NAME:	Cedar Grove Market (Demo)
ADDRESS OF SERVICE:	25 Demo Lane, Kerrville, TX 78028
BPA LOCATION:	East landscape enclosure
BPA SERVES:	Landscape irrigation

Submit this form to:
City of Kerrville Public Works Dept.
PWS ID: 1330001
701 Main Street
Kerrville, TX 78028
Or to: chris.clark@kerrvilletx.gov

The backflow prevention assembly detailed below has been tested and maintained as required by commission regulations and is certified to be operating within acceptable parameters.

TYPE OF BACKFLOW PREVENTION ASSEMBLY (BPA):

☒	Reduced Pressure Principle (RPBA)	☐	Reduced Pressure Principle-Detector (RPBA-D) Type II	☐	
☐	Double Check Valve (DCVA)	☐	Double Check-Detector (DCVA-D) Type II	☐	
☐	Pressure Vacuum Breaker (PVB)	☐	Spill-Resistant Pressure Vacuum Breaker (SVB)		

	Manufacturer	Model Number	Serial Number	Size
Main:	Watts	009M2	DEMO-RPZ-001	1 inch
Bypass:				

Reason for test:	New ☐	Existing ☒	Replacement ☐	Old Model/Serial #
Is the assembly installed in accordance with manufacturer recommendations and/or local codes?	☒ Yes	☐ No		
Is the assembly installed on a non-potable water supply (auxiliary)?	☐ Yes	☒ No		

TEST RESULT **PASS** ☒ **FAIL** ☐	Reduced Pressure Principle Assembly (RPBA)			Type II Assembly	PVB & SVB	
	DCVA		Relief Valve	Bypass Check	Air Inlet	Check Valve
	1st Check	2nd Check***				
Initial Test Date: 11/05/2026 Time 9:15 AM	Held at 5.2 psid Closed Tight ☐ Leaked ☐	Held at ____ psid Closed Tight ☒ Leaked ☐	Opened at 2.8 psid Did not open ☐	Held at ____ psid Closed Tight ☐ Leaked ☐	Opened at ____ psid Did not open ☐ Did it fully open (Yes ☐ / No ☐)	Held at ____ psid Leaked
Repairs and Materials Used**	Main: Bypass:					
Test After Repair Date: Time:	Held at ____ psid Closed Tight ☐	Held at ____ psid Closed Tight ☐	Opened at ____ psid	Held at ____ psid Closed Tight ☐	Opened at ____ psid	Held at ____ psid

*** 2nd check: numeric reading required for DCVA only

Differential pressure gauge used:	Potable: Yes	Non-Potable:
Make/Model: Mid-West 845	SN: DEMO-GAUGE-01	Date tested for accuracy : 01/15/2026

Remarks: Demonstration only - fictional readings; not for submission.

Company Name:	BackflowCore Demo	Licensed Tester Name (Print/Type):	Alex Rivers
Company Address:	100 Demo Way, Kerrville, TX	Licensed Tester Name (Signature):	DEMO - unsigned
Company Phone #:	(830) 555-0142	BPAT License #	DEMO-NOT-VALID
		License Expiration Date:	11/05/2027

The above is certified to be true at the time of testing.

* TEST RECORDS MUST BE KEPT FOR AT LEAST THREE YEARS [30 TAC §290.46(B)]
** USE ONLY MANUFACTURER'S REPLACEMENT PARTS